From: Nelson, Denise L

To: Bolstridge, Karen

Subject: Re: [EXTERNAL] Amendment B to Development Permit DP 5050_ Proposed 300-Foot Lighted

Telecommunications Tower with Access Road and Utility Line.

Date: Friday, August 06, 2021 4:48:57 PM

Attachments: <u>image002.png</u>

dp5050b AgencyReviewRequest.pdf

APPA Letter to LUPC Rising Tide Tower 2021-08-06.pdf

NPS Rising Tide Tower Viewshed Map.pdf

EXTERNAL: This email originated from outside of the State of Maine Mail System. Do not click links or open attachments unless you recognize the sender and know the content is safe. Hi Karen,

Comments from the NPS on the Rising Tide Tower pending application are attached. Please let me know if you have any questions.

Thank you,

Denise

Denise L. Nelson Environmental Protection Specialist Appalachian National Scenic Trail P.O. Box 50 (Deliveries: 252 McDowell St.) Harpers Ferry, WV 25425

301-512-5573 (mobile)
304-535-6292 (office) *currently unattended*
denise nelson@nps.gov

From: Bolstridge, Karen < Karen. Bolstridge@maine.gov>

Sent: Friday, July 16, 2021 9:24 AM

To: Rodrigues, David <David.Rodrigues@maine.gov>; Libbey, Ken <Ken.Libbey@maine.gov>; Hallowell, Dawn <Dawn.Hallowell@maine.gov>; St.Hilaire, Lisa <Lisa.St.Hilaire@maine.gov>; Nelson, Denise L <Denise_Nelson@nps.gov>; Mohney, Kirk <Kirk.Mohney@maine.gov>; Rideout, Megan M <Megan.M.Rideout@maine.gov>; IFWEnvironmentalreview

<IFWEnvironmentalreview@maine.gov>; Stratton, Robert D <Robert.D.Stratton@maine.gov>; Perry, John <John.Perry@maine.gov>; Hulsey, Charles <Charles.Hulsey@maine.gov>; Thorndike, Elizabeth <Elizabeth.Thorndike@maine.gov>; Maine Field Office, FW5 <mainefieldoffice@fws.gov>; Mahaney, Wende <wende_mahaney@fws.gov>; LeeAnn.Neal@usace.army.mil

<LeeAnn.Neal@usace.army.mil>; Jaramillo, Haley <Haley.Jaramillo@maine.gov>;
townmanager@rangeleyme.org <townmanager@rangeleyme.org>; 'dallasplt@myfairpoint.net'
<dallasplt@myfairpoint.net>; sandyriver@myfairpoint.net <sandyriver@myfairpoint.net>;
rangplt@myfairpoint.net <rangplt@myfairpoint.net>; jmagoon@franklincountymaine.gov
<jmagoon@franklincountymaine.gov>

Cc: Godsoe, Benjamin <Benjamin.Godsoe@maine.gov>; Bolstridge, Karen <Karen.Bolstridge@maine.gov>

Subject: [EXTERNAL] Amendment B to Development Permit DP 5050_ Proposed 300-Foot Lighted Telecommunications Tower with Access Road and Utility Line.

This email has been received from outside of DOI - Use caution before clicking on links, opening attachments, or responding.

This sender might be impersonating a domain that's associated with your organization. <u>Learn why</u> this could be a risk

All:

Please review and comment on the project noted in the subject line and attached form above. Please let me know if you are not going to submit comments or if you think someone else should be receiving this review request.

A note: the application is rather large; here are some .pdf starting page locations that could be helpful in your review.

Wetland information: Page 199

Phosphorus Control Plan information: Page 370 Visual Impact Assessment information: Page 233 Historic Preservation information: Page 232 and VIA Wildlife and Rare Species assessment: Page 151

Soils information: Page 176

Please note that this project is located at a different location on the property and is a different height than the first DP 5050 submittal.

1. I have consolidated and placed the full application and the site plans as of July 08, 2021 on the LUPC FTP site.

To retrieve the application material, you will need a high-speed internet connection and a storage device.

Please follow these steps to retrieve the documents from the LUPC FTP site:

Go to http://www.maine.gov/dacf/lupc/review/

After clicking the link above - a login box will open and you will be prompted to enter a:

User Name: doc

Password: mejuri1 (Note the last character of the password is a one)

then go to Folder Name: LUPC Downeast Region

then go to Folder Name: 1_dp5050b_Application

The File Names are: 20210708_dp5050b_ UpdatedSitePlans.pdf and

20210708_dp5050b_UpdatedApplication.pdf

To download, right-click on the file you want and select the "Save As..." or "Save Target As..." option. Then save the file to your computer.

2. I have attached a link to a webpage for the 300-foot telecommunications tower in Dallas Plantation, Franklin County, Maine.

The webpage includes additional information on the project timeline and will include information on the public hearing when scheduled.

https://www.maine.gov/dacf/lupc/projects/dp5050B/dp5050B.html

Thanks all for your time and effort.

Karen E. Bolstridge

Karen E. Bolstridge, Environmental Specialist III Maine Department of Agriculture, Conservation and Forestry Land Use Planning Commission 106 Hogan Road; Suite 8 Bangor, Maine 04401

Phone: (207) 215-4685 Fax: (207) 941-4222

Email: karen.bolstridge@maine.gov





STATE OF MAINE DEPARTMENT OF AGRICULTURE, CONSERVATION & FORESTRY LAND USE PLANNING COMMISSION 106 HOGAN ROAD, SUITE 8 BANGOR, MAINE 04401

AMANDA E. BEAL COMMISSIONER

JUDY C. EAST EXECUTIVE DIRECTOR

REQUEST FOR A REVIEW AND COMMENT ON PENDING APPLICATION

TO BE CONSIDERED, COMMENTS DUE BY: AUGUST 06, 2021

Date: July 16, 2021 Permit #: DP 5050-B Analyst: Karen Bolstridge

Applicant: Rising Tide Towers, LLC

Location: Dallas Plantation, Franklin County, Maine

Project: Utility facility. 300-foot self-supporting lattice telecommunications tower and associated appurtenances (includes a 2592-foot Level C Road project and a 2615-foot Utility Line. **Special Note(s)**: Please note that this project is located at a different location on the property than the first DP 5050 submittal.

Maine Bureau of Parks and Lands (Lands and Trails)	rails) U.S. Army of Corps of Engineers	
 David Rodrigues - David.Rodrigues@maine.gov 	LeeAnn Neal - LeeAnn.Neal@usace.army.mil	
Maine Department of Environmental Protection	Maine Department of Transportation (Scenic Byway	
(Phosphorus Control Plan Review)	and Roads Review)	
Ken Libbey - Ken.Libbey@maine.gov	Haley Jaramillo - Haley.Jaramillo@maine.gov	
Dawn Hallowell - Dawn.Hallowell@maine.gov		
Maine Natural Areas Program	Town of Rangeley	
Lisa St. Hilaire - Lisa.St.Hilaire@maine.gov	 townmanager@rangeleyme.org 	
National Park Service	Dallas Plantation	
 Denise Nelson - denise_Nelson@nps.gov 	dallasplt@myfairpoint.net	
Maine Historic Preservation Commission	Sandy River Plantation	
Kirk Mohney – Kirk.Mohney@maine.gov	sandyriver@myfairpoint.net	
Megan M. Rideout - Megan.M.Rideout@maine.gov		
Maine Department of Inland Fisheries and Wildlife	Rangeley Planation	
IFWEnvironmentalreview@maine.gov	rangplt@myfairpoint.net	
Robert D Stratton - Robert.D.Stratton@maine.gov		
John Perry - John.Perry@maine.gov		
Charles Hulsey - Charles.Hulsey@maine.gov		
Elizabeth Thorndike -		
Elizabeth.Thorndike@maine.gov		
U.S. Fish & Wildlife Service	Franklin County Commissioners	
 mainefieldoffice@fws.gov 	jmagoon@franklincountymaine.gov	
 Wende Mahaney - Wende_Mahaney@fws.gov 		

After review	w of the application and consideration of the p	proposal's probable impacts, we have:	
No com	ments on the proposal	X Comments on the proposal are attached	
Signature: _	Denise L Nelson	Date: 08/06/2021	
	Reports of staff permitting decisions, can be for	ound here: http://www.maine.gov/dacf/lupc/reports/	

PHONE: 207-215-4685 www.maine.gov/dacf FAX: 207-941-4222

United States Department of the Interior



NATIONAL PARK SERVICE

Appalachian National Scenic Trail P.O. Box 50 (Deliveries: 252 McDowell St.) Harpers Ferry, WV 25425

IN REPLY REFER TO:

1.A.1

August 6, 2021

Maine Land Use Planning Commission c/o Ms. Karen E. Bolstridge, Environmental Specialist III Maine Department of Agriculture, Conservation and Forestry 106 Hogan Road; Suite 8 Bangor, Maine 04401

RE: Proposed 300' Lighted Telecommunications Tower with Access Road and Utility Line – Development Permit 5050, Dallas Plantation, Franklin County, Maine

Dear Ms. Bolstridge:

The National Park Service (NPS) received your request for review and comment on a pending application submitted by Rising Tide Towers for the above referenced new telecommunications tower and associated infrastructure in Franklin County, Maine. The NPS reviewed the materials provided and offers the following initial comments regarding potential impacts of this proposal on the Appalachian National Scenic Trail (ANST or Trail) for your consideration.

ANST Description

The Appalachian National Scenic Trail is an approximately 2,193-mile-long continuous, skyline hiking path that traverses the scenic, wooded, pastoral, wild, and culturally resonant lands of the Appalachian Mountains from Georgia to Maine. The Trail was conceived in 1921 and originally built and maintained by a consortium of agencies and private citizens. Congress officially recognized the national significance of the ANST when it designated the Trail one of the first National Scenic Trails with the passage of the National Trails System Act (NTSA) in 1968. The NPS is charged under the NTSA with administration of the ANST. This charge includes oversight of development, management, and protection of the ANST, which is accomplished through an extensive cooperative management framework with the Appalachian Trail Conservancy, other agencies, and 31 Trail clubs made up of thousands of volunteers.

The NPS has found the Appalachian National Scenic Trail eligible for listing in the National Register of Historic Places (NRHP) as a continuous linear Historic District. The NPS has prepared a multiple property documentation form to guide formal nominations of state Trail segments to the NRHP that is currently under review by the State Historic Preservation Offices in the fourteen states the Trail traverses. The district is recommended as significant at the national level under Criterion A in the areas of Recreation and Conservation and meets Criteria G for properties that have achieved exceptional significance within the past 50 years. Contributing resources include the Trail Treadway, ANST Side Trails, ANST bridges, ANST Viewpoints, and ANST Overnight Use Areas. Cultural landscapes the Trail passes through and

the Trail setting are vital to its significance as both a historic and recreational resource and to the Trail visitor experience.

Project Description

Rising Tide Towers proposes to construct a 300-foot self-support lattice telecommunications tower within a 40,000 square foot lease area located off Dallas Hill Road northeast of Rangeley Lake in Franklin County, Maine. In addition to the tower, an access road and utility line will be constructed from Dallas Hill Road to the lease area. As proposed, the tower would be lighted using a flashing dual (red/white) beacon and side mounted red lights that are designed to illuminate red at night and have medium intensity flashing white light for daytime and twilight.

Potential Impacts on the ANST

An eight-mile Area of Potential Effect was used in the applicant's Visual Impact Analysis to assess impacts to scenic resources. In this area of Maine, tall lighted structures like cell towers and wind turbines may be quite noticeable from the ANST on most days given the vast elevated views from the Trail of the surrounding landscape and air quality. For example, the lights on the turbines at Kibby Wind Farm are visible from the West Peak ANST Vista in the Bigelow Preserve at approximately 20-miles away.

The NPS ran a bare earth viewshed for the proposed tower to estimate its potential to be visible from the ANST (see enclosed map). This analysis indicates that the proposed tower may be visible from several locations on the ANST including ones identified in Rising Tide's viewshed map, Saddleback Mountain and the Horn. These two mountain vistas are just a little over 5 miles from the proposed tower site and the proposed tower and lights will likely be visible from these viewpoints as well as along the Trail treadway given the openness of the Saddleback ridgeline. These two Trail viewpoints are quite accessible and popular destinations for Trail visitors.

In addition, there are several other significant ANST viewpoints shown on this map located more than 5 miles away from the proposed tower from which the tower lights may be visible even if the tower itself is not. We recommend further analysis and consideration of the potential for visual impacts to ANST viewpoints beyond eight miles since the proposal includes lighting the tower. Lighting draws viewer's attention both day and night and lights illuminated at night can adversely impact night sky views.

Potential Minimization Measures

In order to minimize visual effects on the Appalachian National Scenic Trail and other scenic resources, please consider the following potential minimization measures:

- Limit the overall tower height below that which requires lighting, which we understand is typically below 200 feet. (preferred over all other measures) It is our understanding that a 190-foot tower was proposed by Rising Tide in 2019 at a nearby site which suggests that this may be a feasible option to meet service needs.
- Use a radar activated lighting system for tower lights. The applicant mentions that Federal Aviation Administration (FAA) approval of an Aircraft Detection Lighting System (ADLS) is required by the Federal Communications Commission and is granted on a case-by-case basis. We request the option of using an ADLS to reduce light pollution from the proposed tower be further explored for this project by consulting with/seeking FAA review and approval.

- Adhere to night sky-friendly lighting at the telecommunication site compound such as using light only where and when needed, using motion sensor lighting, shield lights and direct all light downward, select lamps with warmer colors, use smaller wattage bulbs.
- Non-reflective, background conforming color scheme on body of the tower and associated fixtures and equipment shelters. For example, painting the tower a dark grey color to blend with the landscape (not just galvanized steel).
- Minimize tree clearing around the site and access road.

Thank you for the opportunity to review and comment on this pending application. We greatly appreciate all efforts to reduce impacts to the nationally significant Appalachian National Scenic Trail. Should you have any questions about our comments, please contact Denise Nelson of my staff at 301-512-5573 or at denise_nelson@nps.gov.

Sincerely,

Wendy K. Janssen Superintendent

Enclosures (1): Viewshed Map

cc: Hawk Metheny, ATC

