

Lincoln/Haney Engineering Associates, Inc.

Structural Engineering Consultants

Michael A. Cunningham, P.E., LEED AP
Thad Gabryszewski, P.E., S.E.
Justin Desjarlais, P.E.

ADDENDUM #1

DATE: June 10, 2023

PROJECT: Administration Building Roof Repair Project
at Bolduc Correctional Facility, Warren, Maine, BGS Project 3424

OWNER: Maine Department of Corrections
25 Tyson Drive
111 State House Station
Augusta, Maine 04333-111

BID DATE: June 15, 2023

The contract documents dated May 22, 2023 are modified in accordance with this addendum as follows:

| | |
|--------------------|--|
| DESCRIPTION | <u>Relating to Drawings</u> <ol style="list-style-type: none">Drawing S1.1 Revise the ROOF FRAMING PLAN to identify new sections and details.Drawing S5.2 Add Details 4/S5.2 and 8/S5.2 and Sections 11/S5.2 and 12/S5.2.Drawing S5.3 Add drawing S5.3.Drawing S5.4 Add drawing S5.4. |
| | <u>Responses to Bidder Questions</u> <ol style="list-style-type: none">Section 2/S5.1 identifies (2) 1" diameter steel rods at a truss. How many of these are required? Response: The section is intended to be typical of 5 trusses. Therefore 10 steel rods are required. |
| ATTACHMENTS | Drawings S0.1, S1.1, S5.1, S5.2, S5.3, S5.4 |

| | |
|--------------------------|--|
| ENGINEER: By: | Lincoln/Haney Engineering Associates, Inc. Michael A. Cunningham, P.E., LEED AP |
|--------------------------|--|