

Table 1016.1 revised

OCCUPANCY	WITHOUT SPRINKLER SYSTEM (feet)	WITH SPRINKLER SYSTEM (feet)
A, F-1, M, R	200	250b
E	150	200
B	200	300c
F-2, U	300	400c
H-1	Not Permitted	75c
H-2	Not Permitted	100c
H-3	Not Permitted	150c
H-4	Not Permitted	175c
H-5	Not Permitted	200c
I-2, I-3, I-4	Not Permitted	200c
S-1, S-2, I-1	See NFPA 101 (2009) Table A7.6	See NFPA 101 (2009) Table A7.6