



DEPARTMENT ORDER

Hancock Lumber Company, Inc.
Somerset County
Pittsfield, Maine
A-932-71-C-R

Departmental
Findings of Fact and Order
Air Emission License
Renewal

FINDINGS OF FACT

After review of the air emission license renewal application, staff investigation reports, and other documents in the applicant's file in the Bureau of Air Quality, pursuant to 38 Maine Revised Statutes (M.R.S.) § 344 and § 590, the Maine Department of Environmental Protection (Department) finds the following facts:

I. REGISTRATION

A. Introduction

Hancock Lumber Company, Inc. (Hancock) has applied to renew their Air Emission License permitting the operation of emission sources associated with their lumber mill.

The equipment addressed in this license is located at 407 Stinson Street in Pittsfield, Maine.

B. Emission Equipment

The following equipment is addressed in this air emission license:

Boilers

Equipment	Maximum Capacity (MMBtu/hr)	Maximum Firing Rate (tons/hour)	Fuel Type	Installation Date	Stack #
Boiler #1	12.6	1.4*	Wood, Sawdust, Trim ends	1985	1

*Based on firing wood with a moisture content of 50%, by weight

Process Equipment

Equipment	Production Rate	Pollution Controls	Installation Date
Drying Kilns #1 - #4	29 MMBF/year	None	1987
Drying Kilns #5 - #6			2005

C. Application Classification

All rules, regulations, or statutes referenced in this air emission license refer to the amended version in effect as of the issued date of this license.

The application for Hancock does not include the licensing of increased emissions or the installation of new or modified equipment. Therefore, the license is considered to be a renewal of currently licensed emission units only and has been processed through *Major and Minor Source Air Emission License Regulations*, 06-096 Code of Maine Rules (C.M.R.) ch. 115.

Because Hancock's maximum annual emissions are below the major source thresholds for all criteria pollutants, Hancock is considered to be a true minor source.

Hancock is licensed below the major source thresholds for hazardous air pollutants (HAP) and is considered an area source of HAP.

II. **BEST PRACTICAL TREATMENT (BPT)**

A. Introduction

In order to receive a license, the applicant must control emissions from each unit to a level considered by the Department to represent Best Practical Treatment (BPT), as defined in 06-096 C.M.R. ch. 100. Separate control requirement categories exist for new and existing equipment as well as for those sources located in designated non-attainment areas.

BPT for existing emissions equipment means that method which controls or reduces emissions to the lowest possible level considering:

- the existing state of technology;
- the effectiveness of available alternatives for reducing emissions from the source being considered; and
- the economic feasibility for the type of establishment involved.

B. Boiler #1

Boiler #1 has a maximum design capacity of 12.6 MMBtu/hour and fires wood, specifically sawdust and trim ends, at a rate of 1.4 tons/hour. Boiler #1 was manufactured by Industrial Boiler Inc. in 1985 and exhausts through Stack #1.

Hancock uses fly ash reinjection for control of particulate matter from Boiler #1.

1. BPT Findings

The BPT emission limits for Boiler #1 were based on the following:

PM/PM ₁₀	0.33 lb/MMBtu, 2005 BACT determination (A-932-71-A-N)
SO ₂	0.025 lb/MMBtu, AP-42 Table 1.6-2, dated 9/03
NO _x	0.22 lb/MMBtu, AP-42 Table 1.6-2, dated 9/03
CO	0.6 lb/MMBtu, AP-42 Table 1.6-2, dated 9/03
VOC	0.017 lb/MMBtu, AP-42 Table 1.6-3, dated 9/03
Opacity	06-096 C.M.R. ch. 115, BPT

The BPT emission limit for Boiler #1 is the following:

Equipment	Pollutant	lb/MMBtu
Boiler #1	PM	0.33

Emissions from Boiler #1 shall not exceed the following:

Equipment	PM (lb/hr)	PM ₁₀ (lb/hr)	SO ₂ (lb/hr)	NO _x (lb/hr)	CO (lb/hr)	VOC (lb/hr)
Boiler #1	4.2	4.2	0.3	2.8	7.6	0.2

Visible emissions from Boiler #1 shall not exceed 20% opacity on a six-minute block average basis, except for no more than two six-minute block averages in a three-hour period, during which time visible emissions shall not exceed 50% opacity.

Hancock shall use the following formula, when necessary, to convert fuel use records to 50% moisture:

$$\text{Tons Wood at 50\%} = (\text{Tons Wood at M\%}) \times [(100-M)/50]$$

where M = the moisture content of the actual wood fired

Hancock shall continuously operate the fly ash reinjection system at all times that Boiler #1 is in operation.

2. New Source Performance Standards (NSPS): 40 C.F.R. Part 60, Subpart Dc

Since Boiler #1 was modified after 1989, it is subject to *Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units* 40 C.F.R. Part 60, Subpart Dc for units greater than 10 MMBtu/hr manufactured after June 9, 1989. [40 C.F.R. § 60.40c]

- a. Hancock shall record and maintain records of the amounts of fuel combusted on a monthly basis. [40 C.F.R. § 60.48c(g)]

- b. The following address for EPA shall be used for any reports or notifications required to be copied to them:

U.S. Environmental Protection Agency, Region I
5 Post Office Square, Suite 100 (OES04-2)
Boston, MA 02109-3912
Attn: Air Compliance Clerk

3. National Emission Standards for Hazardous Air Pollutants (NESHAP):
40 C.F.R. Part 63, Subpart JJJJJ

Boiler #1 is considered an existing biomass boiler and is subject to the *National Emission Standards for Hazardous Air Pollutants for Industrial, Commercial, and Institutional Boilers Area Sources*, 40 C.F.R. Part 63, Subpart JJJJJ. [40 C.F.R. §63.11193 and 63.11195]

A summary of the currently applicable federal 40 C.F.R. Part 63, Subpart JJJJJ requirements is listed below. At this time, the Department has not taken delegation of this area source MACT (Maximum Achievable Control Technology) rule promulgated by EPA; however, Hancock is still subject to the requirements. Notification forms and additional rule information can be found on the following website: <http://www.epa.gov/ttn/atw/boiler/boilerpg.html>.

- a. Compliance Dates, Notifications, and Work Practice Requirements

(1) Initial Notification of Compliance

An Initial Notification submittal to EPA was due no later than January 20, 2014. [40 CFR Part 63.11225(a)(2)]

Hancock submitted their Initial Notification to EPA on September 28, 2011.

(2) Boiler Tune-Up Program

(i) A boiler tune-up program shall be implemented. [40 C.F.R. Part 63.11223]

(ii) Tune-ups shall be conducted on Boiler #1 on a two year interval. [40 CFR Part 63.11223(a) and Table 2]

(iii) The boiler tune-up program, conducted to demonstrate continuous compliance, shall be performed as specified below:

1. As applicable, inspect the burner, and clean or replace any component of the burner as necessary. Delay of the burner inspection until the next scheduled shutdown is permitted, not to exceed 36 months from the previous inspection. [40 C.F.R. § 63.11223(b)(1)]
2. Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern, consistent with the manufacturer's specifications. [40 C.F.R. § 63.11223(b)(2)]
3. Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure it is correctly calibrated and functioning properly. Delay of the inspection until the next scheduled shutdown is permitted, not to exceed 36 months from the previous inspection. [40 C.F.R. § 63.11223(b)(3)]
4. Optimize total emissions of CO, consistent with manufacturer's specifications. [40 C.F.R. § 63.11223(b)(4)]
5. Measure the concentration in the effluent stream of CO in parts per million by volume (ppmv), and oxygen in volume percent, before and after adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made). Measurements may be taken using a portable CO analyzer. [40 C.F.R. § 63.11223(b)(5)]
6. If a unit is not operating on the required date for a tune-up, the tune-up must be conducted within 30 days of start-up.
[40 C.F.R. § 63.11223(b)(7)]

(iv) Tune-Up Report: A tune-up report shall be maintained onsite and, if requested, submitted to EPA. The report shall contain the following information:

1. The concentration of CO in the effluent stream (ppmv) and oxygen (volume percent) measured at high fire or typical operating load both **before** and **after** the boiler tune-up;
2. A description of any corrective actions taken as part of the tune-up of the boiler; and
3. The types and amounts of fuels used over the twelve months prior to the tune-up of the boiler, but only if the unit was physically and legally capable of using more than one type of fuel during that period. Units sharing a fuel meter may estimate the fuel use by each unit.
[40 C.F.R. § 63.11223(b)(6)]

- (v) After conducting the initial boiler tune-up, a Notification of Compliance Status shall be submitted to EPA no later than July 19, 2014. [40 C.F.R. § 63.11225(a)(4) and 40 C.F.R. § 63.11214(b)]

Hancock submitted their Notification of Compliance Status to EPA on July 21, 2014.

(3) Compliance Report

A compliance report shall be prepared by March 1st every two years which covers the previous two calendar years. The report shall be maintained by the source and submitted to the Department and/or to the EPA upon request. The report must include the items contained in §§ 63.11225(b)(1) and (2), including the following: [40 C.F.R. § 63.11225(b)]

- (i) Company name and address;
- (ii) A statement of whether the source has complied with all the relevant requirements of this Subpart;
- (iii) A statement certifying truth, accuracy, and completeness of the notification and signed by a responsible official and containing the official's name, title, phone number, email address, and signature;
- (iv) The following certifications, as applicable:
 - 1. "This facility complies with the requirements in 40 CFR §63.11223 to conduct tune-ups of each boiler in accordance with the frequency specified in this Subpart."
 - 2. "No secondary materials that are solid waste were combusted in any affected unit."
 - 3. "This facility complies with the requirement in 40 CFR §§63.11214(d) to conduct a tune-up of each applicable boiler according to 40 CFR §63.11223(b)."

(4) Energy Assessment

Boiler #1 is subject to the energy assessment requirement as follows:

- (i) A one-time energy assessment was required to be performed by a qualified energy assessor on Boiler #1 no later than March 21, 2014. [40 C.F.R. § 63.11196(a)(3)]

Hancock conducted their one-time energy assessment on September 11, 2014.

- (ii) A Notification of Compliance Status was required to be submitted to EPA no later than July 19, 2014. [40 C.F.R. § 63.11225(a)(4) and 40 C.F.R. § 63.11214(c)]

Hancock submitted their Notification of Compliance Status to EPA on October 27, 2014.

b. Recordkeeping

Records shall be maintained consistent with the requirements of 40 C.F.R. Part 63, Subpart JJJJJJ including the following [40 C.F.R. § 63.11225(c)]:

- (1) Copies of notifications and reports with supporting compliance documentation;
- (2) Identification of each boiler, the date of tune-up, procedures followed for tune-up, and the manufacturer's specifications to which the boiler was tuned;
- (3) Records of the occurrence and duration of each malfunction of each applicable boiler; and
- (4) Records of actions taken during periods of malfunction to minimize emissions, including corrective actions to restore the malfunctioning boiler.

Records shall be in a form suitable and readily available for expeditious review.

EPA requires submission of Notification of Compliance Status reports for tune-ups and energy assessments through their electronic reporting system. [40 C.F.R. § 63.11225(a)(4)(vi)]

C. Kilns

Hancock operates a total of six kilns for drying lumber, with heat being provided by Boiler #1.

Hancock's current air emission license restricts the throughput of the drying kilns to 29.0 million board feet (MMBF/year) of eastern white pine per year, on a calendar-year basis.

VOC emissions released from the kilns during drying have been estimated using data from studies conducted by the National Counsel of the Paper Industry for Air and Stream Improvement (NCASI) and the University of Maine. VOC emissions from the drying of eastern white pine in the kilns were calculated using a factor of 2.26 lbs/1000BF.

Using a VOC emission factor for eastern white pine of 2.26 pounds per thousand board feet (lb/MBF), Hancock has a current licensed potential to emit 32.8 tons/year of VOC per year from kiln operations.

The Department is not aware of any economically feasible equipment for the control of VOCs from the drying kilns, therefore BPT for the kilns is determined to be a yearly throughput limit of 29.0 million board feet, on a calendar-year basis.

D. Parts Washer

Hancock operates a Maxjet Premium Quality aqueous parts washer. The parts washer uses Alkota PW-1000 parts washing detergent, which is in powder form. Therefore, the parts washer is not subject to *Solvent Cleaners*, 06-096 C.M.R. ch. 130.

E. Fugitive Emissions

Visible emissions from a fugitive emission source (including stockpiles and roadways) shall not exceed 20% opacity, except for no more than five minutes in any one-hour period. Compliance shall be determined by an aggregate of the individual fifteen-second opacity observations which exceed 20% in any one hour.

F. General Process Emissions

Visible emissions from any general process source shall not exceed 20% opacity on a six-minute block average basis.

G. Annual Emissions

1. Total Annual Emissions

Hancock shall be restricted to the following annual emissions, on a calendar-year basis.

Total Licensed Annual Emissions for the Facility
Tons/year
(used to calculate the annual license fee)

Equipment	PM	PM ₁₀	SO ₂	NO _x	CO	VOC
Boiler #1	18.2	18.2	1.4	12.1	33.1	0.9
Kilns	-	-	-	-	-	32.8
Total TPY	18.2	18.2	1.4	12.1	33.1	33.7

The tons per year limits were calculated based on Boiler #1 operating 8,760 hours/year and an annual kiln throughput of 29.0 million board feet of lumber.

2. Greenhouse Gases

Greenhouse gases are considered regulated pollutants as of January 2, 2011, through 'Tailoring' revisions made to EPA's *Approval and Promulgation of Implementation Plans*, 40 CFR Part 52, Subpart A, §52.21, *Prevention of Significant Deterioration of Air Quality* rule. Greenhouse gases, as defined in 06-096 C.M.R. 100 (as amended), are the aggregate group of the following gases: carbon dioxide, nitrous oxide, methane, hydrofluorocarbons, perfluorocarbons, and sulfur hexafluoride. For licensing purposes, greenhouse gases (GHG) are calculated and reported as carbon dioxide equivalents (CO₂e).

The quantity of CO₂e emissions from this facility is less than 100,000 tons per year, based on the following:

- the types of fuel being fired;
- the facility's fuel use limit;
- worst case emission factors from the following sources: U.S. EPA's AP-42, the Intergovernmental Panel on Climate Change (IPCC), and 40 CFR Part 98, *Mandatory Greenhouse Gas Reporting*; and
- global warming potentials contained in 40 CFR Part 98.

No additional licensing actions to address GHG emissions are required at this time.

III. AMBIENT AIR QUALITY ANALYSIS

The level of ambient air quality impact modeling required for a minor source is determined by the Department on a case-by case basis. In accordance with 06-096 C.M.R. ch. 115, an ambient air quality impact analysis is not required for a minor source if the total licensed annual emissions of any pollutant released do not exceed the following levels and there are no extenuating circumstances:

Pollutant	Tons/Year
PM	25
PM ₁₀	25
SO ₂	50
NO _x	100
CO	250

The total licensed annual emissions for Hancock are below the emission levels contained in the table above and there are no extenuating circumstances; therefore, an ambient air quality impact analysis is not required as part of this license.

ORDER

Based on the above Findings and subject to conditions listed below, the Department concludes that the emissions from this source:

- will receive Best Practical Treatment,
- will not violate applicable emission standards, and
- will not violate applicable ambient air quality standards in conjunction with emissions from other sources.

The Department hereby grants Air Emission License A-932-71-C-R subject to the following conditions.

Severability. The invalidity or unenforceability of any provision, or part thereof, of this License shall not affect the remainder of the provision or any other provisions. This License shall be construed and enforced in all respects as if such invalid or unenforceable provision or part thereof had been omitted.

STANDARD CONDITIONS

- (1) Employees and authorized representatives of the Department shall be allowed access to the licensee's premises during business hours, or any time during which any emissions units are in operation, and at such other times as the Department deems necessary for the purpose of performing tests, collecting samples, conducting inspections, or examining and copying records relating to emissions (38 M.R.S. § 347-C).
- (2) The licensee shall acquire a new or amended air emission license prior to commencing construction of a modification, unless specifically provided for in Chapter 115. [06-096 C.M.R. ch. 115]
- (3) Approval to construct shall become invalid if the source has not commenced construction within eighteen (18) months after receipt of such approval or if construction is discontinued for a period of eighteen (18) months or more. The Department may extend this time period upon a satisfactory showing that an extension is justified, but may condition such extension upon a review of either the control technology analysis or the ambient air quality standards analysis, or both. [06-096 C.M.R. ch. 115]
- (4) The licensee shall establish and maintain a continuing program of best management practices for suppression of fugitive particulate matter during any period of construction, reconstruction, or operation which may result in fugitive dust, and shall submit a description of the program to the Department upon request. [06-096 C.M.R. ch. 115]
- (5) The licensee shall pay the annual air emission license fee to the Department, calculated pursuant to Title 38 M.R.S. § 353-A. [06-096 C.M.R. ch. 115]

- (6) The license does not convey any property rights of any sort, or any exclusive privilege. [06-096 C.M.R. ch. 115]
- (7) The licensee shall maintain and operate all emission units and air pollution systems required by the air emission license in a manner consistent with good air pollution control practice for minimizing emissions. [06-096 C.M.R. ch. 115]
- (8) The licensee shall maintain sufficient records to accurately document compliance with emission standards and license conditions and shall maintain such records for a minimum of six (6) years. The records shall be submitted to the Department upon written request. [06-096 C.M.R. ch. 115]
- (9) The licensee shall comply with all terms and conditions of the air emission license. The filing of an appeal by the licensee, the notification of planned changes or anticipated noncompliance by the licensee, or the filing of an application by the licensee for a renewal of a license or amendment shall not stay any condition of the license. [06-096 C.M.R. ch. 115]
- (10) The licensee may not use as a defense in an enforcement action that the disruption, cessation, or reduction of licensed operations would have been necessary in order to maintain compliance with the conditions of the air emission license. [06-096 C.M.R. ch. 115]
- (11) In accordance with the Department's air emission compliance test protocol and 40 C.F.R. Part 60 or other method approved or required by the Department, the licensee shall:
 - A. Perform stack testing to demonstrate compliance with the applicable emission standards under circumstances representative of the facility's normal process and operating conditions:
 1. Within sixty (60) calendar days of receipt of a notification to test from the Department or EPA, if visible emissions, equipment operating parameters, staff inspection, air monitoring or other cause indicate to the Department that equipment may be operating out of compliance with emission standards or license conditions; or
 2. Pursuant to any other requirement of this license to perform stack testing.
 - B. Install or make provisions to install test ports that meet the criteria of 40 C.F.R. Part 60, Appendix A, and test platforms, if necessary, and other accommodations necessary to allow emission testing; and

- C. Submit a written report to the Department within thirty (30) days from date of test completion.
[06-096 C.M.R. ch. 115]
- (12) If the results of a stack test performed under circumstances representative of the facility's normal process and operating conditions indicate emissions in excess of the applicable standards, then:
- A. Within thirty (30) days following receipt of such test results, the licensee shall re-test the non-complying emission source under circumstances representative of the facility's normal process and operating conditions and in accordance with the Department's air emission compliance test protocol and 40 C.F.R. Part 60 or other method approved or required by the Department; and
- B. The days of violation shall be presumed to include the date of stack test and each and every day of operation thereafter until compliance is demonstrated under normal and representative process and operating conditions, except to the extent that the facility can prove to the satisfaction of the Department that there were intervening days during which no violation occurred or that the violation was not continuing in nature; and
- C. The licensee may, upon the approval of the Department following the successful demonstration of compliance at alternative load conditions, operate under such alternative load conditions on an interim basis prior to a demonstration of compliance under normal and representative process and operating conditions.
[06-096 C.M.R. ch. 115]
- (13) Notwithstanding any other provisions in the State Implementation Plan approved by the EPA or Section 114(a) of the CAA, any credible evidence may be used for the purpose of establishing whether a person has violated or is in violation of any statute, regulation, or Part 70 license requirement. [06-096 C.M.R. ch. 115]
- (14) The licensee shall maintain records of malfunctions, failures, downtime, and any other similar change in operation of air pollution control systems or the emissions unit itself that would affect emissions and that is not consistent with the terms and conditions of the air emission license. The licensee shall notify the Department within two (2) days or the next state working day, whichever is later, of such occasions where such changes result in an increase of emissions. The licensee shall report all excess emissions in the units of the applicable emission limitation. [06-096 C.M.R. ch. 115]
- (15) Upon written request from the Department, the licensee shall establish and maintain such records, make such reports, install, use and maintain such monitoring equipment, sample such emissions (in accordance with such methods, at such locations, at such intervals, and in such a manner as the Department shall prescribe), and provide other information as the Department may reasonably require to determine the licensee's compliance status.

[06-096 C.M.R. ch. 115]

SPECIFIC CONDITIONS

(16) **Boiler #1**

A. Fuel

Hancock shall fire only wood in Boiler #1, which shall include sawdust and trim ends. [06-096 C.M.R. ch. 115, BPT]

B. Emissions shall not exceed the following:

Equipment	Pollutant	lb/MMBtu	Origin and Authority
Boiler #1	PM	0.33	2005 BACT (A-932-71-A-N)

C. Emissions shall not exceed the following [06-096 C.M.R. ch. 115, BPT]:

Equipment	PM (lb/hr)	PM ₁₀ (lb/hr)	SO ₂ (lb/hr)	NO _x (lb/hr)	CO (lb/hr)	VOC (lb/hr)
Boiler #1	4.2	4.2	0.3	2.8	7.6	0.2

D. Hancock shall continuously operate fly ash reinjection on Boiler #1 whenever Boiler #1 is in operation. [06-096 C.M.R. ch. 115, BPT]

E. Visible emissions from the boiler shall not exceed 20% opacity on a six-minute block average basis, except for no more than two six-minute block averages in a three-hour period during which time visible emissions shall not exceed 50% opacity. [06-096 C.M.R. ch. 115, BPT]

F. Hancock shall comply with all requirements of 40 C.F.R. Part 60, Subpart Dc applicable to Boiler #1 including, but not limited to, the following:

- a. Hancock shall record and maintain records of the amounts of fuel combusted on a monthly basis. [40 C.F.R. § 60.48c(g)]
- b. The following address for EPA shall be used for any reports or notifications required to be copied to them:

U.S. Environmental Protection Agency, Region I
5 Post Office Square, Suite 100 (OES04-2)
Boston, MA 02109-3912
Attn: Air Compliance Clerk

G. Boiler MACT (40 C.F.R. Part 63, Subpart JJJJJ) Requirements for Boiler #1 [incorporated under 06-096 C.M.R. ch. 115, BPT]

1. The facility shall implement a boiler tune-up program. [40 C.F.R. § 63.11223]
 - a. Tune-ups shall be conducted on Boiler #1 on a two year interval. [40 C.F.R. Part 63.11223(a) and Table 2]
 - b. The boiler tune-up program, conducted to demonstrate continuous compliance, shall be performed as specified below:
 - (1) As applicable, inspect the burner, and clean or replace any component of the burner as necessary. Delay of the burner inspection until the next scheduled shutdown is permitted, not to exceed 36 months from the previous inspection. [40 C.F.R. § 63.11223(b)(1)]
 - (2) Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern, consistent with the manufacturer's specifications. [40 C.F.R. § 63.11223(b)(2)]
 - (3) Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure it is correctly calibrated and functioning properly. Delay of the inspection until the next scheduled shutdown is permitted, not to exceed 36 months from the previous inspection. [40 C.F.R. § 63.11223(b)(3)]
 - (4) Optimize total emissions of CO, consistent with manufacturer's specifications. [40 C.F.R. § 63.11223(b)(4)]
 - (5) Measure the concentration in the effluent stream of CO in parts per million by volume (ppmv), and oxygen in volume percent, before and after adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made). Measurements may be taken using a portable CO analyzer. [40 C.F.R. § 63.11223(b)(5)]
 - (6) If a unit is not operating on the required date for a tune-up, the tune-up must be conducted within 30 days of start-up. [40 C.F.R. § 63.11223(b)(7)]
 - c. Tune-Up Report: A tune-up report shall be maintained onsite and, if requested, submitted to EPA. The report shall contain the following information:
 - (1) The concentration of CO in the effluent stream (ppmv) and oxygen (volume percent) measured at high fire or typical operating load both **before** and **after** the boiler tune-up;

- (2) A description of any corrective actions taken as part of the tune-up of the boiler; and
- (3) The types and amounts of fuels used over the twelve months prior to the tune-up of the boiler, but only if the unit was physically and legally capable of using more than one type of fuel during that period. Units sharing a fuel meter may estimate the fuel use by each unit. [40 C.F.R. § 63.11223(b)(6)]

2. Compliance Report

A compliance report shall be prepared by March 1st biennially which covers the previous two calendar years. The report shall be maintained by the source and submitted to the Department and/or to the EPA upon request. The report must include the items contained in §§ 63.11225(b)(1) and (2), including the following: [40 C.F.R. § 63.11225(b)]

- a. Company name and address;
- b. A statement of whether the source has complied with all the relevant requirements of this Subpart;
- c. A statement certifying truth, accuracy, and completeness of the notification and signed by a responsible official and containing the official's name, title, phone number, email address, and signature;
- d. The following certifications, as applicable:
 - (1) "This facility complies with the requirements in 40 C.F.R. § 63.11223 to conduct tune-ups of each boiler in accordance with the frequency specified in this Subpart."
 - (2) "No secondary materials that are solid waste were combusted in any affected unit."
 - (3) "This facility complies with the requirement in §§ 63.11214(d) and 63.11223(g) to minimize the boiler's time spent during startup and shutdown and to conduct startups and shutdowns according to the manufacturer's recommended procedures or procedures specified for a boiler of similar design if manufacturer's recommended procedures are not available."

3. Records shall be maintained consistent with the requirements of 40 C.F.R. Part 63, Subpart JJJJJ including the following [40 C.F.R. § 63.11225(c)]:

- a. Copies of notifications and reports with supporting compliance documentation;
- b. Identification of each boiler, the date of tune-up, procedures followed for tune-up, and the manufacturer's specifications to which the boiler was tuned;
- c. Records of the occurrence and duration of each malfunction of each applicable boiler; and
- d. Records of actions taken during periods of malfunction to minimize emissions, including corrective actions to restore the malfunctioning boiler.

Records shall be in a form suitable and readily available for expeditious review.

EPA requires submission of Notification of Compliance Status reports for tune-ups and energy assessments through their electronic reporting system. [40 C.F.R. § 63.11225(a)(4)(vi)]

(17) **Kilns**

- A. Hancock shall not exceed a yearly throughput of 29.0 million board feet, on a calendar-year basis. [06-096 C.M.R. ch. 115, BPT]
- B. Hancock shall keep monthly and annual records of board feet processed. [06-096 C.M.R. ch. 115, BPT]

(18) **Fugitive Emissions**

Visible emissions from a fugitive emission source (including stockpiles and roadways) shall not exceed 20% opacity, except for no more than five minutes in any one-hour period. Compliance shall be determined by an aggregate of the individual fifteen-second opacity observations which exceed 20% in any one hour. [06-096 C.M.R. ch. 115, BPT]

(19) **General Process Sources**

Visible emissions from any general process source shall not exceed 20% opacity on a six-minute block average basis. [06-096 C.M.R. ch. 115, BPT]

(20) **Annual Emission Statement**

In accordance with *Emission Statements*, 06-096 C.M.R. ch. 137, the licensee shall annually report to the Department, in a format prescribed by the Department, the information necessary to accurately update the State's emission inventory. The emission statement shall be submitted as specified by the date in 06-096 C.M.R. ch. 137.

Hancock Lumber Company, Inc.
Somerset County
Pittsfield, Maine
A-932-71-C-R

17

Departmental
Findings of Fact and Order
Air Emission License
Renewal

- (21) Hancock shall notify the Department within 48 hours and submit a report to the Department on a quarterly basis if a malfunction or breakdown in any component causes a violation of any emission standard (38 M.R.S. § 605).

DONE AND DATED IN AUGUSTA, MAINE THIS 16 DAY OF March, 2017.

DEPARTMENT OF ENVIRONMENTAL PROTECTION

BY: Marc Allen Robert Corne for
PAUL MERCER, COMMISSIONER

The term of this license shall be ten (10) years from the signature date above.

[Note: If a renewal application, determined as complete by the Department, is submitted prior to expiration of this license, then pursuant to Title 5 M.R.S. § 10002, all terms and conditions of the license shall remain in effect until the Department takes final action on the license renewal application.]

PLEASE NOTE ATTACHED SHEET FOR GUIDANCE ON APPEAL PROCEDURES

Date of initial receipt of application: December 16, 2015

Date of application acceptance: December 22, 2015

Date filed with the Board of Environmental Protection:

This Order prepared by Kevin J Ostrowski, Bureau of Air Quality.

