

System Losses Central Maine Power Company

<u>Voltage Category</u>	<u>Winter Energy Losses</u>	<u>non-Winter Energy Losses</u>	<u>Average Energy Losses</u>
Transmission	0.23%	0.34%	0.30%
Subtransmission	1.37%	1.49%	1.44%
Primary ¹	3.87%	3.87%	3.92%
Secondary	7.27%	7.66%	7.52%
Average			6.10%

System losses exclude losses over PTF facilities. Central Maine Power Company's winter months are December through March. CMP's Line Loss Study may be obtained by contacting the Maine Public Utilities Commission at 207-287-3831 and referencing Docket No. 98-943.

¹ It is likely that such things as rounding within internal modeling calculations account for the fact that the average energy loss is larger than both seasonal losses.